

**STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013**

**FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
VALENCIA WATER COMPANY
(Well Nos. N7 AND N8)**

**NPDES NO. CAG 994001
CI-8466**

FACILITY ADDRESS

Valencia Boulevard & Cinema Drive
Valencia, CA 91355

FACILITY MAILING ADDRESS

24631 Avenue Rockefeller
Valencia, CA 91355

PROJECT DESCRIPTION:

The Valencia Water Company proposes to discharge groundwater associated with the developments and the conducting of pumping tests, on Well No. N7 and N8, located at Valencia Boulevard and Cinema Drive respectively, Valencia. The groundwater from the project will be discharged to the South Fork Santa Clara River. A desilting tank will be installed to allow sediment to settle before discharging.

VOLUME AND DESCRIPTION OF DISCHARGE:

Up to 6.0 million gallons per day (mgd) of groundwater will be discharged during the short-term pumping test that will be conducted over a period of five working days. The discharge will be released from the facility into the South Fork of the Santa Clara River, a water of the United States. The site location map is shown in Figure 1. The discharge outfall locations are listed below:

<u>Outfall No.</u>	<u>Latitude</u>	<u>Longitude</u>
001	34° 25' 39"	118° 35' 29"
002	34° 25' 56"	118° 35' 53"

FREQUENCY OF DISCHARGE:

The discharge will be intermittent. The project is proposed to be initiated in October 2002.

REUSE OF WATER:

Water reuse options, such as dust control and irrigation, were evaluated. However, they were considered infeasible at the site. Therefore, the groundwater will be discharged into South Fork Santa Clara.